



VENTILATION NOTE:
 4 1/2" dia. 4400 CFM FANS REQUIRED 18'-0" O.C.
 FANS 2 AND 4 SET TIMER ON 2 MINUTES OUT
 OF 10 AND SET THERMOSTATS 50°F
 FAN 1 SET THERMOSTAT ON 65°F
 FAN 3 SET THERMOSTAT ON 80°F

NOTE:
 CONSULT LOCAL HEALTH AUTHORITIES
 BEFORE STARTING CONSTRUCTION TO BE
 SURE THAT THE PLAN CONFORMS WITH
 LOCAL CODES AND REGULATIONS

V.P.L. PLAN 6113

COOPERATIVE EXTENSION WORK IN
 AGRICULTURE AND HOME ECONOMICS
 DEPARTMENT OF AGRICULTURAL ENGINEERING
 UNIVERSITY OF MARYLAND
 FINISHING FLOOR
 FOR 400 PIGS

VP	70	6104	SHEET 1 OF 3
----	----	------	--------------